

SPRINKLER SYSTEMS

Per Ordinance No. 2010-388 all new structures (see reverse side for definition of a new structure) or substantial additions/alterations to an existing structure where the remodel combined with any additions to the structure affects 50% or more of the exterior wall plane surface or affects 50% or more of the floor area within a 12 month period, shall be equipped with an automatic sprinkler system.

The following structures are exempt from these requirements:

- Agricultural Buildings, "Agricultural building is defined as a non-residential structure designed and constructed to house farm implements, hay, grain, poultry, livestock, or other horticultural products." "Agricultural buildings" shall include greenhouses.
- Non-Residential structures not exceeding 1,000 square feet in area

Plan Requirements

The Woodside Fire Protection District is responsible for plan check, inspection & testing, and approval of the sprinkler system.

Applications shall be made directly to WFPD.

**Woodside Fire Protection District
4091 Jefferson Ave
Redwood City, CA 94062**

(650) 851-6206
(650) 366-1973 fax