

INDOOR WATER USE EFFICIENCY CHECKLIST

To Be Completed by Applicant

I certify that the subject project meets the specified requirements of the Indoor Water Use Efficiency Ordinance.

Signature _____

Date _____

Project Information

Single Family Multi-Family Commercial Institutional Irrigation only Industrial Other:

Applicant Name (print): _____

Contact Phone #: _____

Project Site Address: _____

Project Area (sq.ft. or acre): _____

of Units: _____

of Water Meters: _____

Fixture	Requirements			Number of Devices and Unit Water Use	Agency Review	
	Single-Family and Multi-Family Residential	Non-Residential	Units		(Pass)	(Fail)
Toilets	< 1.28	< 1.28	gpf		<input type="checkbox"/>	<input type="checkbox"/>
Urinals - Wall Mounted	≤1.25	≤1.25	gpf		<input type="checkbox"/>	<input type="checkbox"/>
Urinals - Non Wall Mounted	≤0.5	≤ 0.5	gpf		<input type="checkbox"/>	<input type="checkbox"/>
Single Shower Head	≤1.8 at 80 PSI	≤1.8 at 80 PSI	gpm		<input type="checkbox"/>	<input type="checkbox"/>
Multiple Shower Heads Serving One Shower	Combined flow rate of all shower heads ≤1.8 at 80 PSI	Combined flow rate of all shower heads ≤1.8 at 80 PSI	gpm		<input type="checkbox"/>	<input type="checkbox"/>
Lavatory faucets	Min.- .8 @ 20 PSI Max.-1.2 @80 PSI	≤.5 @ 60 PSI	gpm		<input type="checkbox"/>	<input type="checkbox"/>
Lavatory faucets in Common and Public Use Areas	≤.5 @ 60 PSI	≤.5 @ 60 PSI	gpm		<input type="checkbox"/>	<input type="checkbox"/>
Metering Faucets	≤.2 per cycle	≤.2 per cycle	gpm		<input type="checkbox"/>	<input type="checkbox"/>
Kitchen faucets	≤ 1.8 @ 60 PSI	≤ 1.8 @ 60 PSI	gpm		<input type="checkbox"/>	<input type="checkbox"/>
Prerinse Spray Valve - Class 1	≤ 1	≤ 1	gpm		<input type="checkbox"/>	<input type="checkbox"/>
Prerinse Spray Valve - Class 2	≤ 1.2	≤ 1.2	gpm		<input type="checkbox"/>	<input type="checkbox"/>
Prerinse Spray Valve - Class 3	≤ 1.8	≤ 1.8	gpm		<input type="checkbox"/>	<input type="checkbox"/>
Clothes washers	≤ 6.0	≤ 6.0	Water Factor		<input type="checkbox"/>	<input type="checkbox"/>
Dishwashers	≤ 6.5 or Energy Star	Energy Star	gal/cycle		<input type="checkbox"/>	<input type="checkbox"/>
Cooling towers	--	≥ 5 to 10 or ≥ 2.5	cycles LSI		<input type="checkbox"/>	<input type="checkbox"/>
Food steamers	--	Boilerless or Self-Contained	--		<input type="checkbox"/>	<input type="checkbox"/>

INDOOR WATER USE EFFICIENCY CHECKLIST

Ice machines	--	≤ 25 or Air-cooled	gal/100 lbs ice		<input type="checkbox"/>	<input type="checkbox"/>
Pre-rinse spray valves	≤ 1.15	≤ 1.15	gpm		<input type="checkbox"/>	<input type="checkbox"/>
Automatic vehicle wash facilities	--	> 50% of the water is recycled	--		<input type="checkbox"/>	<input type="checkbox"/>
Commercial refrigeration	--	Closed loop or Air-cooled	--		<input type="checkbox"/>	<input type="checkbox"/>
Water Meters	--	Submeters	--		<input type="checkbox"/>	<input type="checkbox"/>
	Separate meter for outdoor if landscape is greater than 5,000 sq.ft.	Separate meter for outdoor if landscape is greater than 5,000 sq.ft.	--		<input type="checkbox"/>	<input type="checkbox"/>

INDOOR WATER USE EFFICIENCY CHECKLIST

To Be Completed by Agency

Page 2 of 2

Auditor:

Materials Received and Reviewed:

- Indoor Water Use Efficiency Checklist
- Project Plans

Date Reviewed:

- Follow up required (explain):

Date Resubmitted:

Date Approved:

Material Distributed to Applicant

- Indoor Water Use Efficiency Ordinance
- Information on qualifying fixtures and appliances
- Other:

Measures Recommended to Applicant

- On-demand/tankless water heater
- Leak detection methods
- Water-efficient landscaping
- Other:

Comments:

Selected Definitons:

gal/100 lbs ice	gallons per hundred pounds of ice
gal/cylce	gallons per cycle
gpf	gallons per flush
gpm	gallons per minute
LSI	Langlier Saturation Index
sq.ft.	square feet
>	greater than
≤	less than or equal to
≥	greater than or equal to